



CLEMENTON BUREAU OF FIRE SAFETY

101 Gibbsboro Road

Clementon, NJ 08021

Office: 856-783-0284 Ext 123 Fax: 856-783-3419

**EMERGENCY AND EXIT LIGHTING LOG
30 SECONDS PER MONTH/1 HOUR PER YEAR**

THIS DOCUMENT SHALL BE SECURELY ATTACHED TO THE WALL IN CLOSE PROXIMITY TO THE MAIN ELECTRICAL CIRCUIT BREAKER PANEL

	<u>Exit Signs Operational</u>	<u>Emergency Lights Operational</u>	<u>Tested By</u>	<u>Explain "No" and Date Repaired</u>
January	_____	_____	_____	_____
February	_____	_____	_____	_____
March	_____	_____	_____	_____
April	_____	_____	_____	_____
May	_____	_____	_____	_____
June	_____	_____	_____	_____
July	_____	_____	_____	_____
August	_____	_____	_____	_____
September	_____	_____	_____	_____
October	_____	_____	_____	_____
November	_____	_____	_____	_____
December	_____	_____	_____	_____

THE ONE (1) HOUR ANNUAL TESTING OF THE EMERGENCY LIGHTING SYSTEM WAS CONDUCTED ON

_____ AND FOUND OPERTIONAL.

DEFICIENCIES NOTED ARE: _____

CORRECTED ON: _____